


Conductor Deformation

PREFERRED



Wires are not scraped, flattened, untwisted, buckled, kinked or otherwise deformed.

ACCEPTABLE



Where strands were straightened during the insulation removal, they have been retwisted to the original lay of the wire.

REJECT



Birdcaging (spreading of strands) has made any strands of wire extend beyond the insulation thickness. The general spiral lay of the strands has not been maintained.

FISCHER-BACKUS CORP.

COLUMBUS, OH

**DRAWING
NUMBER**

92-0007-0

TITLE

QC STANDARDS, CONDUCTOR DEFORMATION

DATE 10-1-86

Sheet 1 **of** 1

DRAWN DCB

APPROVED *DCB*